

ACCESSORY KIT INSTALLATION INSTRUCTIONS

COIL GUARD ACCESSORY MODELS 1CG0403 and 1CG0404

For 7.5 Through 20 Ton Split-System Outdoor Units



WARNING: Cancer and Reproductive Harm –
www.P65Warnings.ca.gov.

General

The coil guard is designed to prevent damage to the condenser coil of the unit. The following tables list the compatible units.

Table 1: 1CG0403 compatible units

Unit capacity	Condenser unit model
7.5, 15 ton	YC090, YE090, YC/YD180, YH-07, YK-07, YH/YJ-15, J07YC, J07YE, J15YC/YD YHT07, YKT07, YH/YJT15
	PC090, PE090, PC/PD180, PH-07, PK-07, PH/PJ-15, J07PC, J07PE, J15PC/PD PHT07, PKT07, PH/PJT15

Table 2: 1CG0404 compatible units

Unit capacity	Condenser unit model
10, 12.5, 20, 25 ton	YC/YD120, 150, 240, YC300 YH/YJ-10, -12, -20, YH-25 J10, 15, 20YC/YD, J25YC YH/YJT10, T12, T20, YHT25
	PC/PD120, 240, PH/PJ-10, -20, J10, 20PC/PD PH/PJT10, T20

Kit contents

The following tables list the kit contents. Verify the contents of the kit before you begin installation.

Table 3: 1CG0403 kit contents

Item	Qty.	Description
1	2	Wire grill
2	16	Nylon washer
3	16	#10 x .5 in. screw

Table 4: 1CG0404 kit contents

Item	Qty.	Description
1	4	Wire grill
2	16	Nylon washer
3	16	#10 x .5 in. screw

Installing the accessory

1. Verify the correct model number and the number of parts.
2. Install the coil guard according to the following figures. Pay attention to details A and B.




Figure 1: 1CG0403 installed




Figure 2: Installing 1CG0404